

PROFORMA REGARDING SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATENo. 407Date: 30.7.2025It is certified that an inspection team headed by Susendra Kumar Sharma

Junior Chemist (Name of Officers with designation) from PHED Laboratory, Jhunjhunu (Name of Department/Office) Inspected the CEERI Vidya Mandir, CSEER-CEERS School) on 30.7.25 and found that the CEERI Vidya Mandir

Pilani (Name of school) has safe drinking water facilities for the students and members of staff of the institution and is maintaining the hygienic sanitation condition in the school building & the campus as per the norms prescribed by the Central/State/U.T Govt.

The above valid for a period of ONE years

Signature with Seal: \_\_\_\_\_

Name : \_\_\_\_\_

Designation : \_\_\_\_\_

(सुरेन्द्र कुमार शर्मा)  
कनिष्ठ रसायनज्ञ  
जन स्वा० अभि० विभाग  
प्रयोगशाला, झुंझुनू

To The principal  
CEERI Vidya Mandir  
Pilani - 333031 (Raj.)

(Name &amp; Address of the Institution)

Principal

**Principal**  
**Ceeri Vidya Mandir**

Pilani, Distt.-Jhunjhunu (Raj.)-333081

(Signature)  
Secretary/सचिव  
CEERI Educational Society  
राजस्थान शैक्षणिक समिति  
पिन-333031 (Rajasthan)  
पिना-333031 (राजस्थान)



**PUBLIC HEALTH ENGINEERING DEPARTMENT  
LABORATORY JHUNJHUNU**

**CHEMICAL EXAMINATION REPORT OF WATER**

No. Lab. / Chem. /2025-26/ 407

Date - 30.7.2025

To,  
The Principal  
CEERI Vidya Mandir  
Pilani

District - Jhunjhunu

Tehsil:- Pilani


Ref- Your letter no.cvm/water/2025-26 dated 29-07-2025

Date of Exam -30-07-2025


A	Name & Location of Source	IS-10500:2012		RO Filter CEERI Vidya Mandir	TW CEERI Vidya Mandir
B	Village/ Town			Pilani	Pilani
C	Date Of Collection			29-07-2025	29-07-2025
D	Lab. Sample No.			C-64	C-65
Sr. No	Parameters	Desirable limits	Permissible limits	Value	
1	pH	6.5—8.5	6.5—8.5	6.90	7.68
2	Turbidity[NTU]	1	5	Nil	Nil
3	Temperature[C]	-----	-----	25	25
4	Colour[Units]	5 Hazen Unit	15 Hazen Unit	None	None
5	Odour	Unobjectionable	Unobjectionable	Unobj.	Unobj.
6	Residual Chlorine	0.2	1.0	Nil	Nil
7	Total Alkalinity[asCaCO <sub>3</sub> ]	200	600	20	340
8	Total Hardness[asCaCO <sub>3</sub> ]	200	600	36	320
9	Chloride[asCl <sup>-1</sup> ]	250	1000	20	370
10	Nitrate[as NO <sub>3</sub> <sup>-1</sup> ]	45	45	2	16
11	Fluoride [as F <sup>-1</sup> ]	1.0	1.5	0.15	1.80
12	Sulphate [as SO <sub>4</sub> <sup>-2</sup> ]	200	400	03	380
13	TDS	500	2000	85	1420

Note:1- All Results Except pH in mg/L.

2- This report is not valid for legal cases/legal purposes.

  
(S K Sharma)  
Junior Chemist  
PHED Laboratory Jhunjhunu

  
Principal  
Ceeri Vidya Mandir  
Pilani, Distt.-Jhunjhunu (Raj.)-333081

  
Secretary/सचिव  
CEERI Educational Society  
शैक्षणिक समिति  
333031 (Rajasthan)  
पिन-333031 (Rajasthan)